

CHART FOR SECTION H SUMMARY OF LOADS BY PART

Part No.	Description	Ultimate Load Load (Lbs.)	Average Allowable Load (Lbs.)
A-J62	Adjust-A-Jaw® Tensioner	2173	1085
A-J82	Adjust-A-Jaw® Tensioner	3134	1565
A-J122	Adjust-A-Jaw® Tensioner	4262	2130
A-JTB6	Adjust-A-Body® Tensioner	2022	1010
A-JTB8	Adjust-A-Body® Tensioner	3320	1660
A-JTE62	Adjust-A-Body® Tensioner	2120	1060
A-JTE82	Adjust-A-Body® Tensioner	3364	1680
F-4	Ferrule	1416	705
F-6	Ferrule	2022	1010
F-8	Ferrule	3134	1565
F-10	Ferrule	4262	2130
F-12	Ferrule	3560	1780
F-J62	Fixed Jaw	2317	1155
F-J82	Fixed Jaw	4010	2005
F-J122	Fixed Jaw	4315	2155
F-T6-5B	Fixed Tab	2317	1155
F-T8-5B	Fixed Tab	4010	2005
R-6-12 thru R-6-52	Receiver	2652	1325
R-8-22 thru R-8-52	Receiver	3248	1620
R-12-32 thru R-12-52	Receiver	4595	2295
RF-4	Radius Ferrule	1580	790
RF-6	Radius Ferrule	2286	1140
RF-8	Radius Ferrule	4092	2045
RF-10	Radius Ferrule	4068	2030
RF-12	Radius Ferrule	3762	1880
S-4	Threaded Stud	1537	765
S-6	Threaded Stud	2652	1325
S-8	Threaded Stud	3248	1620
S-10	Threaded Stud	4595	2295
S-12	Threaded Stud	3994	1995
TT-6B	Threaded Tab	2120	1060
TT-8B	Threaded Tab	4262	2130
W-R6-5A	Welded Receiver (See Note)	2106	1050
W-R8-5A	Welded Receiver (See Note)	2335	1165

Note: Welded Receiver tested in un-welded configuration.

PREPARED BY THE CABLE CONNECTION TO SUMMARIZE CALCULATIONS IN SECTION H, LABORATORY TESTING OF CABLE HARDWARE COMPONENTS.

6
9/1/06

Ultra-tec
CABLE RAILING SYSTEMS



1-800-851-2961 ■ 775-885-1443 ■ Fax 775-885-2734
52 Heppner Drive ■ Carson City, NV 89706
E-mail: info@ultra-tec.com Website: www.ultra-tec.com